

Model National Energy Code for Buildings & SB-10 - PROJECT INFORMATION

Form 1

Project:	Location of Project:
Building Permit Application No.:	Date:

Designer Information	Designer Information
Signature _____ Date(YY/MM/DD) _____	Signature _____ Date(YY/MM/DD) _____
Name _____ Title _____	Name _____ Title _____
Address _____	Address _____
City _____ Province _____	City _____ Province _____

Designer Information	Designer Information
Signature _____ Date(YY/MM/DD) _____	Signature _____ Date(YY/MM/DD) _____
Name _____ Title _____	Name _____ Title _____
Address _____	Address _____
City _____ Province _____	City _____ Province _____

THIS CHECKLIST IS A CONVENIENCE DOCUMENT ONLY AND IS BASED ON THE PROVISIONS DESCRIBED IN THE **CCBFC "MODEL NATIONAL ENERGY CODE FOR BUILDINGS"** AND THE **SUPPLEMENTARY STANDARD SB-10**, AS PRESCRIBED IN DIVISION B, SENTENCE 12.2.1.1.(2) OF THE ONTARIO BUILDING CODE.

THIS CHECKLIST IS NOT A SUBSTITUTE FOR COMPLYING WITH THE REQUIREMENTS OF THE ONTARIO BUILDING CODE. WHILE CARE HAS BEEN TAKEN TO ENSURE ACCURACY OF THIS CHECKLIST, DESIGNERS AND BUILDING OFFICIALS MUST REFER TO THE ACTUAL WORDING AND REQUIREMENTS OF THE ONTARIO BUILDING CODE (O.REGS 350/06 AND ITS AMENDMENTS).

THIS CHECKLIST IS PREPARED BY THE MEMBERS OF THE MECHANICAL SERVICES ADVISORY COMMITTEE (MSAC). MSAC IS A SUBCOMMITTEE OF THE TORONTO AREA CHIEF BUILDING OFFICIALS COMMITTEE AND DRAWS ITS MEMBERSHIP FROM BOTH THE PUBLIC AND PRIVATE SECTORS. THE MINISTRY OF MUNICIPAL AFFAIRS AND HOUSING AND MSAC MEMBERS DO NOT ASSUME RESPONSIBILITY FOR ERRORS OR OVERSIGHTS RESULTING FROM THE INFORMATION CONTAINED HEREIN.

PLEASE FILL IN THE ACTUAL VALUES INSTALLED AND CHECK BOXES AS THEY APPLY.

Model National Energy Code for Buildings & SB-10 - COMPLIANCE SUMMARY**Form 2**

Project:	Location of Project:
Building Permit Application No.:	Designer Name:

Mandatory Provisions

The building design complies with the provisions of the following sections:

Code Reference	Compliance Column	Additional Forms/Comments
3.2 BUILDING ENVELOPE	<input type="checkbox"/> YES	
4.2 LIGHTING	<input type="checkbox"/> YES	
5.2 HEATING, VENTILATING AND AIR CONDITIONING	<input type="checkbox"/> YES	
6.2 SERVICE WATER HEATING SYSTEMS AND EQUIPMENT	<input type="checkbox"/> YES	
7.2 ELECTRICAL POWER	<input type="checkbox"/> YES	

Method of Additional Compliance: Prescriptive Compliance & System Performance
 Performance Compliance

Prescriptive Compliance

The building design complies with the Prescriptive Compliance of the following sections:

Code Reference	Compliance Column	Additional Forms/Comments
Part 3 BUILDING ENVELOPE _____ Prescriptive Requirements (5.5 of SB-10) _____ System Performance Method (5.6 of SB-10)	<input type="checkbox"/> YES	
Part 4 LIGHTING _____ Prescriptive Requirements	<input type="checkbox"/> YES	
Part 5 HVAC SYSTEMS _____ Prescriptive Requirements	<input type="checkbox"/> YES	
Part 6 SERVICE WATER HEATING _____ Prescriptive Requirements	<input type="checkbox"/> YES	

Building Energy Performance Compliance

The building design complies with the provisions of Part 8 of the MNECB because the Annual Adjusted Energy Consumption is equal to or less than, the Building Energy Target, as determined by the Ontario version of the *EE4-CODE* software program or equivalent

 YES**Notes:**

Building Design must comply with either the Prescriptive Requirements or the Building Energy Performance Compliance. Indicate which method was selected.

Project:	Designer Name:
----------	----------------

Envelope Summary		
	Compliance Column	Additional Forms
Envelope is designed in accordance with applicable sections of SB-10	<input type="checkbox"/> YES	
Electric space heating is used	<input type="checkbox"/> YES <input type="checkbox"/> NO	
SB-10 5.3.1. Overall Thermal Resistance		
SB-10 5.3.2. Thermal transmittance (Ui) of an Individual Path Through an Envelope Assembly U –values are calculated as per ASHRAE Handbook of Fundamentals and in accordance with prescribed procedures, including fenestration and shading coefficients.	<input type="checkbox"/> YES	
Air Leakage and Moisture Migration Building Envelope meets the air infiltration requirements and is designed to prevent moisture migration	<input type="checkbox"/> YES	
Shell Buildings Is this a shell building?	<input type="checkbox"/> YES <input type="checkbox"/> NO	
Compliance with Prescriptive Method	<input type="checkbox"/> YES <input type="checkbox"/> NO	
SB-10 Tables used:		
Summary of Prescriptive Requirements		
External Wall Criteria	Design	Criteria
Gross wall area (GWA)	_____	_____
Fenestration Area (FA)	_____	_____
Window-wall ratio (FA/GWA)	_____	_____
Fenestration SC - dx	_____	_____
Fenestration PF	_____	_____
Fenestration U-value	_____	_____
Wall U-value	_____	_____
Heat capacity (HC)	_____	_____
Insulation position	_____	_____
Equipment Power Density	_____	_____
Lighting Power Density	_____	_____
Skylights 5% of the gross roof area or less	_____	_____
Skylights - min U-value of 3.97 W/m ² ·K	_____	_____
Other Envelope Components		
<u>U-Values</u>		
Roof	_____	_____
Wall adjacent to unconditioned space	_____	_____
Floors over unconditioned space	_____	_____
<u>R-Values</u>		
Wall below grade	_____	_____
Slab-on-grade <input type="checkbox"/> Heated <input type="checkbox"/> Unheated	_____	_____
<input type="checkbox"/> Horizontal <input type="checkbox"/> Vertical		
Width _____ Height _____		
	<input type="checkbox"/> YES	
	<input type="checkbox"/> YES or <input type="checkbox"/> N/A	
	<input type="checkbox"/> YES or <input type="checkbox"/> N/A	
	<input type="checkbox"/> YES or <input type="checkbox"/> N/A	
	<input type="checkbox"/> YES or <input type="checkbox"/> N/A	

Compliance with System Performance Method	<input type="checkbox"/> YES <input type="checkbox"/> NO	
ENSVTD 23 or 24 is used and passes	<input type="checkbox"/> YES	
ENVSTD 23 or 24 output is attached	<input type="checkbox"/> YES	<input type="checkbox"/> ENVSTD 23 or 24

Project:	Designer Name:
----------	----------------

Mandatory Provisions		
Reference	Code Compliance	Code Compliance
	Internal and External Lighting Power Allowances taken from Supplement to MNECB, Chapter 3 of SB-10	<input type="checkbox"/> YES <input type="checkbox"/> N/A
4.2.1	EXTERIOR LIGHTING POWER	
4.2.1.1	High Efficacy Lighting -efficacy of applicable lamps ≥ 60 lumens/watt	<input type="checkbox"/> YES <input type="checkbox"/> N/A
4.2.1.2	Entrance & Exit Lighting -connected Exterior Lighting Power (_____ kW) \leq total of Lighting Power Allowances from Table 4.2.1.2 of SB-10 (_____ KW)	<input type="checkbox"/> YES <input type="checkbox"/> N/A
4.2.2	EXTERIOR LIGHTING CONTROLS	
	Requirements -exterior lighting controlled by timers and/or photocells	<input type="checkbox"/> YES <input type="checkbox"/> N/A
4.2.3	INTERIOR LIGHTING POWER	
4.2.3.1	Exit Signs -power requirements for individual Exit signs ≤ 22 W	<input type="checkbox"/> YES <input type="checkbox"/> N/A
4.2.4.	INTERIOR LIGHTING CONTROLS	
4.2.4.1	Requirements for Controls -all interior lighting systems provided with required controls	<input type="checkbox"/> YES <input type="checkbox"/> N/A
4.2.4.2	Controls for Night Lighting -lower lighting levels for specified office spaces	<input type="checkbox"/> YES <input type="checkbox"/> N/A
4.2.4.3	Location of Controls -lighting control locations as per provisions in the MNECB	<input type="checkbox"/> YES <input type="checkbox"/> N/A
4.2.4.4	Controls of Hotel Guest Rooms -master switches provided	<input type="checkbox"/> YES <input type="checkbox"/> N/A
4.2.5.	BALLASTS	
	Fluorescent Lamp Ballasts - conform to Table 9.1.5.1. of SB-10	<input type="checkbox"/> YES <input type="checkbox"/> N/A

Prescriptive Compliance (not required if using Part 8)		
Reference	Code Compliance	Code Compliance
4.3.1	INTERIOR CONNECTED LIGHTING POWER	
4.3.1.1	Limits: Total interior connected lighting power (ICLP - _____ W) \leq value of interior lighting power allowance (ILPA - _____ W) determined by using Table 4.3.2.1 or 4.3.3.4 of SB-10	<input type="checkbox"/> YES <input type="checkbox"/> N/A
4.3.2	CALCULATION OF INTERIOR LIGHTING POWER ALLOWANCE BY BUILDING TYPE	
4.3.2.1	Interior Lighting Power Allowance (ILPA) by Building Type: Building Type _____ (Table 4.3.2.1. of SB-10) Lighting Power Density _____ W/m ² (Table 4.3.2.1. of SB-10) Gross Lighted Area _____ m ² ILPA _____ W	<input type="checkbox"/> YES <input type="checkbox"/> N/A
4.3.3	CALCULATION OF INTERIOR LIGHTING POWER ALLOWANCE BY SPACE FUNCTION	
	Calculation of Interior Lighting Power Allowance for each space based on Table 4.3.3.4 of SB-10	<input type="checkbox"/> YES <input type="checkbox"/> N/A

Notes:

N/A – not applicable: i.e. system not in building, exception from code applies, alternate compliance path chosen, etc.
 “MNECB” refers to the Model National Energy Code of Canada for Buildings, 1997

Project:	Designer Name:
----------	----------------

Mandatory Provisions		
Reference		Code Compliance
5.2.1.	EQUIPMENT SIZING	
5.2.1.1.	Load Calculations - system designed in accordance with OBC	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.2.	AIR DISTRIBUTION SYSTEMS	
5.2.2.1.	Design and Installation of Ducts – ducts designed and installed in accordance with OBC	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.2.2.	Provision for Balancing – ducts designed so they can be balanced	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.2.3.	Duct sealing - ducts sealed in accordance with 5.2.2.3. or tested in accordance with 5.2.2.4.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.2.4.	Duct Leakage Testing - ducts not constructed, installed and sealed as per 5.2.2.3.to be tested and to pass as per 5.2.2.4.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.2.5.	Duct and Plenum Insulation - ducts insulated as per provisions of 5.2.2.5.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.2.6.	Protection of Duct Insulation - duct insulation protected as per provisions of 5.2.2.6.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.3.	AIR INTAKE AND OUTLET DAMPERS	
5.2.3.1.	Required Dampers - dampers installed on all air intakes and discharges (exceptions)	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.3.2.	Type and Location of Dampers - dampers designed and installed as per 5.2.3.2.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.4.	PIPES FOR HEATING AND COOLING SYSTEMS	
5.2.4.1.	Design and Installation of Piping – piping designed and installed in accordance with OBC	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.4.2.	Provision for Balancing - hydronic systems designed so they can be balanced	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.4.3.	Piping Insulation - all piping thermally insulated as per provisions in 5.2.4.3. (exceptions)	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.4.4.	Protection of Piping Insulation - piping insulation protected as per provisions of 5.2.4.4.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.5.	PUMPING SYSTEM DESIGN	
5.2.5.1.	Application - applies to HVAC systems with total pumping power>7.5 kW	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.5.2.	Variable-Flow Pumping Systems - systems with variable fluid flow are capable of reducing system flow to 50% or less (exceptions)	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.6.	EQUIPMENT INSTALLED OUTDOORS	
5.2.6.1.	Manufacturer’s Designation - equipment designated by manufacturer for outdoor use	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.7.	ELECTRIC HEATING SYSTEMS	
5.2.7.1.	Electric Resistance Heater Units - baseboard heaters have remotely-mounted thermostats	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.7.2.	Line-voltage Thermostats - line-voltage thermostats conform to CSA C273.4-M	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.8.	RECESSED HEATERS	
5.2.8.1.	Insulation behind recessed heaters – heaters on outside walls meet provisions of 5.2.8.1.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.9.	AIR DISTRIBUTION SYSTEMS SERVING SPACES WITH SPECIAL REQUIREMENTS	
5.2.9.1.	Separate Air Distribution Systems - spaces with special process temperature and/or humidity requirements meet provisions of 5.2.9.1.	<input type="checkbox"/> YES <input type="checkbox"/> N/A

Notes:

N/A – not applicable: i.e. system not in building, exception from code applies, alternate compliance path chosen, etc.
 “MNECB” refers to the Model National Energy Code of Canada for Buildings, 1997

Project:	Designer Name:
----------	----------------

Mandatory Provisions		
Reference		Code Compliance
5.2.10.	TEMPERATURE CONTROLS	
5.2.10.1.	System Temperature Control - each HVAC comfort system has at least one thermostat - each dwelling unit has at least one thermostat	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.10.2	Temperature Control within Dwelling Units - each room has means for reducing heating	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.10.3	Characteristics of Thermostatic Controls - heating minimum setpoint ≤ 13°C - cooling maximum setpoint ≥ 29°C	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.10.4	Installation of Thermostats - location meets provisions of this Article	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.10.5	Heat Pump Controls - thermostat prevents unnecessary use of supplemental heat	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.10.6	Space Temperature Control - control of system meets provisions of this Article	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.10.7	Ice and snow melting heater controls - controls are accessible, labelled, have indicator light	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.11	HUMIDIFICATION	
5.2.11.1	Humidification Controls - automatic controls provided, min/max setpoint 30%/60%	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.12	SHUTOFF AND SETBACK	
5.2.12.1.	Off-hours Controls - each HVAC system has automatic energy reducing off-hours controls meeting provisions of this Article (exceptions)	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.12.2.	Air-Flow control Areas - each air distribution system serving multiple temperature control zones > 2500m ² is divided into air flow control zones as per provisions of this Article (exceptions)	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.12.3.	Seasonal Shutdown - seasonal pumping systems controlled as per provisions of this Article	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.12.4.	Multiple Boilers - multi-boiler systems prevent heat loss from non-operating boilers	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.2.13.	EQUIPMENT EFFICIENCY	
5.2.13.1.	Unit Packaged Equipment – equipment efficiencies meet/exceed the efficiency values given in Tables 6.8.1.A to 6.8.1.G in Chapter 2 of SB-10	<input type="checkbox"/> YES <input type="checkbox"/> N/A

Notes:

N/A – not applicable: i.e. system not in building, exception from code applies, alternate compliance path chosen, etc.
 “MNECB” refers to the Model National Energy Code of Canada for Buildings, 1997

Project:	Designer Name:
----------	----------------

Prescriptive Compliance (not required if using Part 8)		
Reference		Code Compliance
5.3.1	FAN SYSTEM DESIGN	
5.3.1.1	Application - applies to all HVAC fan systems with total fan motor nameplate ratings > 10 kW, except when part of a package unit rated for overall efficiency	
5.3.1.2	Constant-volume Fan Systems - power demand for combined supply and return fan system motors is ≤ 1.6 W per L/s of supply air at design conditions	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.3.1.3	Variable- air-volume Fan Systems – power demand for combined supply and return fan system motors is ≤ 2.65 W per L/s of supply air at design conditions - any individual fan with power demand > 7.5 kW and < 25 kW can reduce power demand to 55% at airflow of 50% - any individual fan with power demand > 25kW can reduce power demand to 30% at airflow of 50%	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> YES <input type="checkbox"/> N/A
5.3.2	COOLING WITH OUTDOOR AIR	
5.3.2.1	Cooling with Outdoor Air Required – each system with mechanical cooling and airflow > 1500 L/s or cooling of > 20 kW has an economizer	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.3.2.2	Cooling by Direct Use of Outdoor Air (Air Economizer System) - each system is capable of using up to 100% outdoor air for cooling, with automatic temperature or enthalpy control and capability for simultaneous outdoor air cooling and mechanical cooling - system(s) with cooling capacity ≥ 70 kW have capacity control to 25%: for cooling capacity 25kW – 70 kW capacity control to 50%	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> YES <input type="checkbox"/> N/A
5.3.2.3	Cooling by Indirect Use of Outdoor Air (Water Economizer System). Systems using: -direct or indirect evaporation capable of supplying 100% cooling load at OD WB temperature ≤ 7°C - systems using sensible heat transfer provide 100% of load at OD WB ≤ 10°C	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> YES <input type="checkbox"/> N/A
5.3.3	CONTROL OF HEATING, VENTILATING AND AIR CONDITIONING SYSTEMS	
5.3.3.1	Control of Temperature of Air Leaving the Supply Air Handler - controls prevent heating cooled air, cooling heated air and heating outdoor air in excess of minimum quantity required for ventilation (exceptions)	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.3.3.2	Control of Space Temperature by Reheating or Recooling. Systems using: - reheat have controls to adjust temperature to match zone needing lowest T air - recool have controls to adjust temperature to match zone needing highest T air - mixing must meet both reheat and recool requirements - primary airflow reduction and with zone supply ≤ 2 L/s per m ² are exempt	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> YES <input type="checkbox"/> N/A
5.3.4	HEAT RECOVERY	
5.3.4.1	Heat Recovery from Dehumidification in Swimming Pools - systems recover minimum 40% of sensible heat from indoor pool exhaust if pool < 10 m ² and has no other non-portable dehumidification system of adequate capacity (see MNECB)	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.3.4.2	Heat Recovery from Ice-Making Machines in Ice Arenas and Curling Rinks - where heating is required heat recovery is provided	<input type="checkbox"/> YES <input type="checkbox"/> N/A
5.3.4.3	Heat Recovery on Dwelling Units - electrically heated dwelling units with self contained ventilation systems have heat recovery on the exhaust which meets heat recovery efficiency provisions of this Article	<input type="checkbox"/> YES <input type="checkbox"/> N/A

Notes:

N/A – not applicable: i.e. system not in building, exception from code applies, alternate compliance path chosen, etc.
 “MNECB” refers to the Model National Energy Code of Canada for Buildings, 1997

MNECB & SB-10 PART 6 SERVICE WATER HEATING SYSTEMS

Form 6

Project:	Designer Name:
----------	----------------

Mandatory Provisions		
Reference	Description	Code Compliance
6.2.1	SYSTEM DESIGN	
6.2.1.1	Regulations - system designed in accordance with OBC Part 6	<input type="checkbox"/> YES <input type="checkbox"/> N/A
6.2.2	STORAGE VESSELS AND HEATING EQUIPMENT	
6.2.2.1	Equipment Efficiency - equipment efficiencies meet/exceed provisions of Table 7-8 in Chapter 2 of SB-10	<input type="checkbox"/> YES <input type="checkbox"/> N/A
6.2.2.2	Location of Heating Equipment – heaters located in conditioned space	<input type="checkbox"/> YES <input type="checkbox"/> N/A
6.2.3	PIPING	
6.2.3.1	Type of system: _____ Circulating _____ Non-circulating _____ Pipe Insulation - conforms to provisions of this Article	<input type="checkbox"/> YES <input type="checkbox"/> N/A
6.2.4	CONTROLS	
6.2.4.1	Temperature Control – systems with storage tanks have automatic temperature controls	<input type="checkbox"/> YES <input type="checkbox"/> N/A
6.2.4.2	Shutdown - systems with storage tanks > 100 L have means for system shutoff	<input type="checkbox"/> YES <input type="checkbox"/> N/A
6.2.4.3	Electric Heat Maintenance Systems -electric heat pipe tracing cables have automatic temperature controls	<input type="checkbox"/> YES <input type="checkbox"/> N/A
6.2.5	SYSTEMS WITH MORE THAN ONE END USE DESIGN TEMPERATURE	
	Remote or Booster Heaters - used when less than 50% of rated flow must be > 60°C	<input type="checkbox"/> YES <input type="checkbox"/> N/A
6.2.7	SWIMMING POOLS	
	Controls - pool heaters have an accessible On/Off switch separate from thermostat - pumps and heaters turn off automatically when not in use (exceptions)	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> YES <input type="checkbox"/> N/A
	Pool Covers - heated swimming pools & hot tubs have pool covers which conform to provisions of this Article	<input type="checkbox"/> YES <input type="checkbox"/> N/A

Prescriptive Compliance (not required if using Part 8)		
Reference	Description	Code Compliance
6.3.1	COMBINATION EQUIPMENT	
6.3.1.1	Combination Service Water and Space Heating Equipment - only permitted if: the total input < 45 kW: or if the input to the combination equipment < (2 x the design service water heating load)	<input type="checkbox"/> YES <input type="checkbox"/> N/A
6.3.1.2	Space Heating Equipment Used for Service Water Heating - equipment used for either SWH or both SWH and space heating meets minimum efficiencies specified in Table 6.8.1.A to Table 6.8.1.G	<input type="checkbox"/> YES <input type="checkbox"/> N/A

Notes:

N/A – not applicable: i.e. system not in building, exception from code applies, alternate compliance path chosen, etc.
 “MNECB” refers to the Model National Energy Code of Canada for Buildings, 1997

Project:

Designer Name:

Mandatory Provisions		
Reference		Code Compliance
7.2.1	ELECTRICAL DISTRIBUTION SYSTEM	
7.2.1.1	Metering - individual metering provided for dwelling units and suites (exceptions)	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.2.1.2	Monitoring - distribution systems > 250 kVA are designed to have energy consumption monitoring installed as per provisions of this Article (exceptions)	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.2.2	POWER CONTROLS	
7.2.2.1	Controls for Power Receptacles – exterior receptacles have one receptacle controlled by switch or timer - receptacles for parking and supplied from suite panel are controlled by switch or timer	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> YES <input type="checkbox"/> N/A
7.2.3	TRANSFORMERS	
7.2.3.1	Transformer Selection - transformers comply with Ontario Energy Efficiency Act and with CAN/CSA-C802 where applicable	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.2.4	ELECTRICAL MOTORS	
	The minimum nominal efficiency for electric motors meets the requirements of Table 10.8 in Chapter 2 of SB-10.	<input type="checkbox"/> YES <input type="checkbox"/> N/A

Notes:

N/A – not applicable: i.e. system not in building, exception from code applies, alternate compliance path chosen, etc.
 “MNECB” refers to the Model National Energy Code of Canada for Buildings, 1997

