



### Notes:

- ALL DIMENSIONS ARE IN MILLIMETERS.
- ALL GATE MATERIAL MUST BE GALVANIZED AFTER FABRICATION.
- ALL 40mm DIAMETER PIPE MUST BE STANDARD SCHEDULE 40 NEW BUTT WELD PIPE.
- GATE POST TO EXTEND A MINIMUM OF 1050mm INTO FOUNDATION SLEEVE PIPE.
- PIN IS WELDED TO GATE WITH A 300mm LONG GALVANIZED CHAIN.
- DIRECTIONAL SIGNAGE TO BE A MINIMUM 1.5mm TK ALUMINUM OR GALVANIZED METAL AND PLACED ON EACH SIDE OF GATE. SIGNS TO BE FASTENED TO GATE WITH RIVETS AT EACH CORNER.
- ALL WELDING, GALVANIZING DRIPS AND SPATTERS TO BE REMOVED AND GROUND SMOOTH.