



Notes:

1. ALL DIMENSIONS ARE IN MILLIMETERS.
2. FINISHED GRANULAR SURFACE TO BE CROSS-SLOPED AT 2%.
3. GRANULAR BASE MATERIAL TO BE IN ACCORDANCE WITH O.P.S.S. 1010.
4. ENSURE THAT ALL ORGANIC MATTER IS REMOVED FROM THE EXCAVATED AREA PRIOR TO PLACING AND COMPACTION OF BASE MATERIALS.
5. MINIMUM DEPTHS ARE SHOWN. REFER TO GEOTECHNICAL RECOMMENDATIONS FOR ADDITIONAL INFORMATION.
6. PATHWAY TO BE DESIGNED IN ACCORDANCE WITH THE CITY OF OSHAWA ENGINEERING STANDARDS.
7. 1000mm BEYOND EITHER SIDE OF THE TRAIL SHALL REMAIN CLEAR OF ALL OBSTRUCTIONS WITH THE EXCEPTION OF WASTE RECEPTACLES, TRAIL ACCESS CONTROL FEATURES, AND BARRIER GUARDS OR UNLESS OTHERWISE SPECIFIED.
8. THE SURFACE AREAS DIRECTLY ADJACENT TO PATHWAY ARE TO BE SOD OVER 300mm OF SCREENED TOPSOIL UNLESS OTHERWISE SPECIFIED. ENSURE POSITIVE DRAINAGE DIRECTED AWAY FROM THE TRAIL WITH A MAXIMUM SLOPE OF 6:1.